



101 Lucas Valley Road, Suite 300
San Rafael, CA 94903
Tel.: 415-472-1734
Fax: 415-499-7715
www.LGVSD.org

MANAGEMENT TEAM
General Manager, Curtis Paxton
Plant Operations, Mel Liebmann
Collections/Safety/Maintenance, Greg Pease
Engineering, Michael P. Cortez
Administrative Services, Dale McDonald

DISTRICT BOARD
Megan Clark
Ronald Ford
Craig K. Murray
Gary E. Robards
Crystal J. Yezman

ADDENDUM NO. 1

Date: July 31, 2023
Project: **John Duckett Force Main Access Structures**
Job No.: 20200-01

To: All Planholders and Prospective Bidders

The following changes and/or clarifications are hereby made to the Contract Documents and shall become a part of the Contract Documents dated July 2023.

Questions Received from Proposers/Bidders:


The following questions were submitted on or before 7/27/2023, questions that are received after the bid questions deadline may not be answered in addendum. LGVSD responses to the questions are in bold.

1. On Sheet C-3.1 Detail 1 (Force Main Access Structure #1) What is the depth of the force main? We have the depth of the access structure to install but need the depth of the force main at that location for the isolation valve we are to install.
Response: The invert elevation of the force main at the location of the isolation valve on Detail 1 (Sheet C-3.1) is +1.0 ft. Please be advised that the invert information is based on as-builts and it is the contractor's responsibility to confirm the location and the invert of the pipeline through the potholing program as stated in the plan notes and specifications.
2. On Sheet C-3.1 Detail 5 (Force Main Access Structure #5). What is the invert elevation at that location?
Response: The invert elevation of the force main at the location Force Main Access Structure #5 (Detail 5, Sheet C-3.1) is -0.5 ft (0.5 ft below sea level). Please be advised that the invert information is based on as-builts and it is the contractor's responsibility to confirm the location and the invert of the pipeline through the potholing program as stated in the plan notes and specifications.
3. I have a question on the sewer line it is a human waste or city sewer line?
Response: The force main conveys wastewater from the John Duckett Pump Station to the wastewater treatment plant, which is owned and maintained by the Las Gallinas Valley Sanitary District.

This addendum consists of two (2) pages including this page and attachments. Acknowledge receipt of this addendum in the space provided on page 93 of 351, Proposal Cover Page and Bid Schedule, of the Bid Forms, and by signing in the space provided below. Submit an original copy of this addendum cover page along with the bid. Failure to do so may disqualify the bidder.

Addendum No. 1
John Duckett Pump Station Force Main Access point
July 31, 2023

Las Gallinas Valley Sanitary District:



Michael P. Cortez, PE, District Engineer

Bidder: _____

(Authorized Signature)

(Date)