



101 Lucas Valley Road, Suite 300  
 San Rafael, CA 94903  
 Tel.: 415-472-1734  
 Fax: 415-499-7715  
 www.LGVSD.org

**MANAGEMENT TEAM**  
 General Manager, Curtis Paxton  
 Plant Operations, Mel Liebmann  
 Collections/Safety/Maintenance, Greg Pease  
 Engineering, Michael P. Cortez  
 Administrative Services, Dale McDonald

**DISTRICT BOARD**  
 Megan Clark  
 Ronald Ford  
 Craig K. Murray  
 Gary E. Robards  
 Crystal J. Yezman

**ADDENDUM NO. 3**

Date: September 19, 2023  
 Project: **Secondary Effluent Line Modifications**  
 Job No.: 12600-07

To: All Planholders and Prospective Bidders

The following changes and/or clarifications are hereby made to the Contract Documents and shall become a part of the Contract Documents dated August 2023.

1. **Statement of Experience of Bidder:** For the District to consider the Bidder properly experienced in work of similar nature to this project, the Bidder must list at least **\$3,000,000** in construction volume on no more than five (5) projects completed within the last five (5) years of the following types of projects:
  - a. **Wastewater treatment plant and/or collection system projects.**

**Questions Received from Proposers/Bidders:**

*The following questions were submitted on or before 9/19/2023, questions that are received after the bid questions deadline may not be answered in addendum. LGVSD responses to the questions are in bold.*

1. Section 338000 paragraph 2.1 states manholes are to be T-Locked Line. Our precast supplier(s) did not include any lining of the manholes. Questions: Are the manhole barrels and tops to be T-Locked Lined? This is a big difference in cost and availability. Addendum needs to be issued to address this specification.

**Response: PVC T-Lock liner is no longer required for precast concrete manhole barrels due to product availability and time constraints.**

This addendum consists of one (1) page including this page and attachments. Acknowledge receipt of this addendum in the space provided on page 95 of 658, Proposal Cover Page and Bid Schedule, of the Bid Forms, and by signing in the space provided below. Submit original copy of this addendum cover page along with the bid. Failure to do so may disqualify the bidder.

Las Gallinas Valley Sanitary District:

Bidder: \_\_\_\_\_

Michael P. Cortez, PE, District Engineer

(Authorized Signature)

(Date)