



101 Lucas Valley Road, Suite 300  
San Rafael, CA 94903  
Tel.: 415-472-1734  
Fax: 415-499-7715  
www.LGVSD.org

**MANAGEMENT TEAM**  
General Manager, Curtis Paxton  
Plant Operations, Mel Liebmann  
Collections/Safety/Maintenance, Greg Pease  
Engineering, Michael P. Cortez  
Administrative Services, Dale McDonald

**DISTRICT BOARD**  
Megan Clark  
Craig K. Murray  
Barry Nitzberg  
Gary E. Robards  
Crystal J. Yezman

## ADDENDUM NO. 2

Date: August 07, 2024  
Project: **Pump Station Lighting Improvements**  
Job No.: 21300-04

To: All Planholders and Prospective Bidders

The following changes and/or clarifications are hereby made to the Contract Documents and shall become a part of the Contract Documents dated June 2024.

### **Questions Received from Proposers/Bidders:**

*The following questions were submitted on or before 8/07/2024, questions that are received after the bid questions deadline may not be answered in an addendum. LGVSD responses to the questions are in bold.*

1. Please, review sheet E109 and clarify if Lighting Deck Plan is for showing the existing panel "A" location only and does not represent the current project's scope of work, such as 2" conduit for PG&E, 2" conduit for future telephone service, lights, float switches, etc. Confirm, that the real scope of work for this project is depicted on sheet E109 Lighting Site Plan only.

**Response: Correct**

**Drawing E109 Lighting Deck Plan only shows existing Panelboard A as the power source, shown in bold. All other work except for the ATS is screened back as existing. There is no equipment on the Lighting Deck Plan within this current project's scope of work other than the circuit breaker within Panelboard A. All new construction under this scope is shown in bold on the Lighting Site Plan.**

2. Please clarify if there are 2 or 3 pole mounted light fixtures and Smith Ranch Pump Station. Plan sheet E103 shows only 2 pole mounted light fixtures, but the lighting schedule on sheet E901 shows 3.


**Response: There are two new pole mounted light fixtures at this site as shown on E103. LF4 will not be installed.**

Addendum No. 2  
Pump Station Lighting Improvements  
August 7, 2024

This addendum consists of two (2) pages including this page and attachments. Acknowledge receipt of this addendum in the space provided on page 93 of 315, Proposal Cover Page and Bid Schedule, of the Bid Forms, and by signing in the space provided below. Submit an original copy of this addendum cover page along with the bid. Failure to do so may disqualify the bidder.

Las Gallinas Valley Sanitary District:

Bidder: \_\_\_\_\_



\_\_\_\_\_

Michael P. Cortez, PE, District Engineer

(Authorized Signature)

(Date)